

May 20, 2019

Slow week this past week...

They installed one lift on the pad down last week, but it was too high in moisture content to pass compaction. They've authorized the use of lime drying as they were unable to make as much progress last week as they had hoped due to the intermittent storms and the wet soil. Lime should help them be less susceptible to weather going forward.

